

Sertifikat Certificate



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs

SERTIFIKAT

☒ O PREGLEDU TIPa / Type examination

Broj / Number: T 1906

☐ POJEDINAČNI PREGLED / Single examination

Strana / Page: 1 / 2

Na zahtev naručioca /
By the request of purchaser:

Vaillant d.o.o. Radnička 57, Beograd, Srbija / Serbia

preduzeto je/
has been undertaken:

Kontrolisanje novog proizvoda
Inspection of the new product

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report:

Broj / Number: T 1906

sa dokumentima u
prilogu/
with attached documents:

- Uputstvo za instaliranje, održavanje i korisnika /
Installation, maintenance instructions and User manual;
- Dokumentacija ugrađenih delova / Documentation of
embedded components;
- Izveštaji o ispitivanju KIWA K 2108 2017 B1 rev.01 ,
161100456 , 161100456/3 i 126030 / Test reports KIWA K
2108 2017 B1 rev.01 , 161100456 , 161100456/3 and 126030

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /
subject of the inspection:

GASNI KONDENZACIONI KOTAO / GAS
CONDENSING BOILER

proizveden od /
manufactured by :

Vaillant GmbH Berghauser Str.40 Remscheid, Nemačka
/ Germany

oznaka - tip - serija /
mark - type - series :

eco TEC plus ...

vrsta/type: B₂₃, B_{53(P)}, C₁₃, C₃₃, C₄₃, C₅₃, C₉₃
kategorija/category: II_{2H3P}

kako je specificirano u Prilogu
A, zadovoljava zahteve
navedene u /
as specified in the Annex A, meets
the requirements listed in:

- Pravilnik o zahtevima za projektovanje, izradu
i ocenjivanje usaglašenosti gasnih aparata ("Sl.
gl. RS", br. 41/2015)
- SRPS EN 15502-2-1:2017

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i
Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012
and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.
Ocenjivanje sprovedeno / Evaluation performed from 19. 02. 2019. ÷ 10.04.2019.

izdat od / issued by :


INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE
Kristina Petković dipl.maš.inž.

mesto, datum izdavanja /
place, date of issue:

Beograd, 10.04.2019.



Ime , Prezime / Name , Surname



SERTIFIKAT

☒ O PREGLEDU TIPa / Type examination

☐ POJEDINAČNI PREGLED / Single examination

Prilog A /
Annex A

Broj / Number:

T 1906

Strana / Page:

2 / 2

oznaka - tip - serija /
mark - type - series :

eco TEC plus ...

vrsta/type: B₂₃, B_{53(P)}, C₁₃, C₃₃, C₄₃, C₅₃, C₉₃
kategorija/category: II_{2H3P}

detaljno oznaka - tip - serija / mark - type - series specification :		tehničke karakteristike / technical characteristics :		kratak opis / short description :	
eco TEC plus ...					
... VU INT 806/5-5	G20*	Qn = 15,2 ÷ 76,2** kW Pn = 14,9 ÷ 74,7** kW	max pritisak grejanja 6 bar / <i>max pressure for heating 6 bar,</i> IPX4D, 230V, 50Hz NOx 5	samo za grejanje/ <i>for heating only</i>	
	G31*	Qn = 38,1 ÷ 76,2** kW Pn = 37,4 ÷ 74,7** kW			
... VU INT 1006/5-5	G20	Qn = 19,2 ÷ 95,2** kW Pn = 18,7 ÷ 93,3** kW			
	G31	Qn = 47,6 ÷ 95,2** kW Pn = 46,7 ÷ 93,3** kW			
... VU INT 1206/5-5	G20	Qn = 22,9 ÷ 114,3** kW Pn = 22,4 ÷ 112,0** kW			
	G31	Qn = 57,2 ÷ 114,3** kW Pn = 56,0 ÷ 112,0** kW			
Napomena/note: *G20: p=20 mbar , G31: p=37 mbar ** Za / For : 80/60 °C					

Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document

Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja
Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one
year within the assessment of the Declaration of Conformity with the type!

Poslednja nadzorna poseta obavljena 16.05.2024.
The last audit was done 16.05.2024.

Sertifikat
Certificate



И 048 19

INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs