



ATC
06-010

КОНТРОЛНО
ТЕЛО
ISO/IEC 17020

SERTIFIKAT O KONTROLISANJU INSPECTION CERTIFICATE

Broj / Number: T 2418

Strana / Page: 1/2

Na zahtev naručioca /
By the request of purchaser:

HERZ Armaturen d.o.o.
Industrijska zona bb, 22330 Nova Pazova
Srbija / Serbia

preduzeto je/
set to:

kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report:

Broj / Number: T 2418

sa dokumentima u prilogu/
with enclosed documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Dokumentacija o proizvodu /
Product documentation;
- Izveštaj o ispitivanju IMP-CGT broj T 2418, DVGW
14/036/4312/154; 18/1040/4312/175 / Test report by
IMP-CGT No. T 2418, DVGW 14/036/4312/154;
18/1040/4312/175

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object :

Kuglasta slavina za unutrašnje gasne instalacije
Ball valve for internal gas installations

proizveden od /
manufactured by :

IMT Armaturen AG, Via Delle Fontane,66
13011 Borgosesia Italy

oznaka - tip - serija /
mark - type - series :

IMT 492 FF ST

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements as described in :

referentnom dokumentu /
reference document :

SRPS EN 331: 2016.

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 .
The inspection certificate is issued basis on the standard SRPS ISO/IEC 17020:2012 .

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa
periodičnim kontrolisanjem do dana /
Surveillance of the inspection object compliance is assured by periodical
inspection until the date :

12.09.2029.

INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impct@pupin.rs

mesto, datum / place, date : **M.P. /**

Beograd, 12.09.2024.



INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE
Kristina Petković dipl.maš.inž.

Ime , Prezime / Name , Surname



ATC
06-010

КОНТРОЛНО
ТЕЛО
ISO/IEC 17020

SERTIFIKAT O KONTROLISANJU INSPECTION CERTIFICATE

Broj / Number: T 2418

Strana / Page: 2/2

Prilog A /

Annex A

oznaka - tip - serija /
mark - type - series :

IMT 492 FF ST

detaljno oznaka - tip - serija / mark - type - series designation:		tehničke karakteristike / technical characteristics :			opis / description :
IMT 492 FF ST		DN	priključci / connections :	najveći radni pritisak / maximum operating pressure :	
49204	1/2"	15	Rp 1/2"	5 bar	Metalna ručna zaporna kuglasta slavina za unutrašnje gasne instalacije, za pritiske MOP 5, sa punim prolazom, sa obostrano unutrašnjim navojnim priključcima / Manually operated metallic ball shut-off valve for internal gas insallations up to MOP 5, with full bore, with internal thread connections on both sides
49206	3/4"	20	Rp 3/4"		
49208	1"	25	Rp 1"		
49210	1 1/4"	32	Rp 1 1/4"		