

Sertifikat Certificate



SERTIFIKAT O PREGLEDU TIPA /

TYPE EXAMINATION CERTIFICATE

T 2536-1

strana / page 1/2

Izdavač sertifikata delujući u okviru svog područja imenovanja i akreditacije, potvrđuje da je identifikovani tip proizvoda vrednovan u odnosu na odredbe iz Pravilnika o aparatima na gasovita goriva - Sl. glasnik RS 60/2023 i da zadovoljava primenljive zahteve za Modul B, za sledeće proizvode / The issuer of the certificate, acting within the framework of its designation and accreditation, confirms that the identified type of product has been evaluated in relation to the provisions of the Ordinance on gas fuel appliances - Sl. gazette RS 60/2023 and that it meets the applicable requirements for Module B, for the following products:

Na zahtev naručioca /
by the request of purchaser

Robert Bosch d.o.o. Omladinskih brigada 90E, 11070
Novi Beograd Srbija / Serbia

Preduzeto je /
has been undertaken:

Sertifikacija gasnog kondenzacionog kotla / Certification of gas
condensing boiler

Proizveden od /
manufactured by :

Bosch Thermotechnik GmbH, Junkers Strasse 20-24, 73249
Wernau, Nemačka / Germany

Proizvodno mesto /
production site

Bosch Thermotechnik Isitma ve Klima San ve Tic A.S. Organize
Sanayi Bölgesi TR-45030 Manisa, Turska / Turkish

Model / model:

Bosch Condens 1200W ...
vrsta/type: B23, C13(x), C33(x), C43(x), C53(x), C63(x), C93(x)
kategorija/category: I2H

Trgovačka oznaka /
trademark:

Bosch Condens 1200W ...

Izveštaj o vrednovanju /
Valuation report:

Broj / No: T 2536-1

Sa dokumentima u prilogu /
with attached documents

videti Prilog A sertifikatu o pregledu tipa / see Annex A to the
type examination certificate

Uslovi važenja i
ograničenja / Validity
conditions and limitations:

Važnost sertifikata je 10 godina od datuma izdavanja i može biti obnovljen na zahtev. Na osnovu ovog sertifikata se ne postavlja srpski znak usaglašenosti. Srpski znak usaglašenosti se može postaviti jedino uz sprovedeno ocenjivanje usaglašenosti sa primenom drugog modula prema Pravilniku o aparatima na gasovita goriva, Sl. glasnik RS 60/2023 / The certificate is valid for 10 years from the date of issue and can be renewed upon request. The Serbian mark of conformity is not placed on the basis of this certificate. The Serbian mark of conformity can only be placed after the evaluation of conformity with the application of the second module according to the Ordinance on Gas Fuel Appliances, Sl. gazette RS 60/2023

U slučaju modifikacija – izmena na proizvodu kojima se utiče na usaglašenost proizvoda, ovaj sertifikat se smatra nevažećim i proizvođač snosi posledice u slučaju njegove primene na tako izmenjene proizvode / In the case of modifications, changes to the product that affect the conformity of the product, this certificate is considered invalid and the manufacturer bears the consequences in case of its application to such modified products

Sertifikacija sprovedena / Evaluation performed from 03.06.2026.

Datum prve sertifikacije / Date of first certification:
21.04.2023.

Datum prethodnog izdanja / Date of previous
issue: 27.06.2025

Datum trenutnog izdanja / Current issue date:
17.06.2026.

Datum prestanka važenja / Expiry date:
16.06.2036.

Beograd 17.06.2026




TEHNIČKI RUKOVODILAC SERTIFIKACIONOG
TELA ZA PROIZVODE

Kristina Petković dipl.maš.inž.

Zabranjeno je umnožavanje izveštaja o vrednovanju i prezentacija rezultata vrednovanja bez prethodno pribavljene saglasnosti IMP- CGT Sertifikacionog tela za proizvode ili klijenta. Provera validnosti izveštaja se vrši putem elektronske pošte. Na izveštaj o vrednovanju i pripadajući sertifikat se može izjaviti prigovor/žalba prema propisanoj proceduri.

INSTITUT MIHAJLO PUPIN DOO BEOGRAD; Volgina 15, 11000, BEOGRAD-ZVEZDARA, Srbija; Matični broj 07014694; PIB 100008310
CENTAR ZA GASNU TEHNIKU • SERTIFIKACIONO TELO ZA PROIZVODE • Telefon: +381 11 6772-151 • e-pošta: impcgt@pupin.rs

CGT 4.607 V.1
Strana: 1 od 2



PRIOLOG A SERTIFIKATU O PREGLEDU TIP A BROJ /

TYPE EXAMINATION CERTIFICATE №

T 2536-1

strana / page 2/2

Datum prvog izdanja / Date of first certification: 21.04.2023.

Datum tekuće izdanje / Current issue date: 17.06.2026.

Datum prethodnog izdanje / Date of previous issue: 27.06.2025

Naziv predmeta sertifikacije / Name of the certification subject:

Gasni kondenzacioni kotao / Gas condensing boiler

Proizvođač / Manufacturer:

Bosch Thermotechnik GmbH, Junkers Strasse 20-24, 73249 Wernau, Nemačka / Germany

Tip / Type:

Bosch Condens 1200W ...

Primenjeni standardi / Applied standards:

SRPS EN 15502 - 2 - 1, SRPS EN 15502 - 1

Izveštaj o ispitivanju / Test report

DVGW B 21/12/3697 EU i B 22/05/3828 EU, DVGW B 26/02/4942 EU

Sa dokumentacijom u prilogu / With documentation attached:

- Uputstvo za instaliranje, i korisnika / Installation, and User manual
- Dokumentacija ugrađenih komponenti / Documentation of embedded components
- Izveštaj o vrednovanju tipa T 2536-1 sa priložima / Evaluation report of type T 2536-1 with attachments

Detaljne tehničke karakteristike / Detailed technical characteristics

detaljno oznaka , tip , serija / mark , type , series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
Bosch Condens ...		
... GC1200W 24 C 23	$Q_n = 5,4 \div 24,6 \text{ kW}$ $Q_{nw} = 5,4 \div 24,6 \text{ kW}$ $P_n = 5,2 \div 24,0 \text{ kW}$ 2H: p=20 mbar PMS=3 bar, T=82°C PMW=10 bar, 230 V, 50 Hz, IP X4D	za grejanje i mogućnost tople sanitarne vode / for heating and domestic hot water
... GC1200W 32 C 23	$Q_n = 6,6 \div 32,7 \text{ kW}$ $Q_{nw} = 6,6 \div 32,7 \text{ kW}$ $P_n = 6,4 \div 32,0 \text{ kW}$	



napomene/notes

Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document