DIN CERTCO
Gesellschaft für Konformitätsbewertung mbH

CERTIFICATE

Certificate holder	**REHAU Industries SE & Co. KG** **Ytterbium 4** **91058 Erlangen** **GERMANY**
Product	Plastic piping and multilayer piping systems for warm water floor heating systems and radiator connecting systems
Type, Model	RAUTHERM NEO-X5
Testing basis	DIN 4726:2017-10 DIN EN ISO 15875-2:2004-03 DIN EN ISO 15875-3:2004-03 DIN EN ISO 15875-5:2004-03 Certification Scheme Plastic piping and multilayer piping sytems for warm water floor heating systems and radiator connecting systems (2019-03)
Mark of conformity	DIN Geprüft
Registration No.	3V455 PE-Xe
Valid until	2028-04-30
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

2023-10-17

Dr. Ina Förster
Certification Body

GESELLSCHAFT FÜR KONFORMITÄTSBEWERTUNG MBH
DIN CERTCO

DIN CERTCO
Gesellschaft für Konformitätsbewertung mbH

ANNEX

Certificate

3V455 PE-Xe dated 2023-10-17

Technical Data

Pipe:
- Name of the manufacturer: REHAU Production LT, UAB
- Production plant: Klaipeda
- Material designation: PE-Xe
- Nominal-outside diameter x nominal thickness (mm): 10.1 x 1.1; 14 x 1.5; 16 x 1.5; 17 x 2.0
- Dimension class: -
- Application class and operating pressure:
Class 4/8 bar & class 5/6 bar
- Pipe with and without velcro wrapping

Fitting/Connector:
- Name of the manufacturer: REHAU Industries SE & Co. KG
- Manufacturing plant: Triptis
- Type of fitting: Sliding sleeve connector
- Material designation: Metal
- Type designation: Mech. metal connectors for plastic pipes (M-MK)

Testing laboratory/ Inspection body

SKZ-Testing GmbH
Friedrich-Bergius-Ring 22
97076 Würzburg
GERMANY

Kiwa Nederland B.V.
Wilmersdorf 50
7327 AC APELDORN
NETHERLANDS

Test report(s)

224552/22-1 von 2023-02-20
224554/22 von 2023-02-20